

# Reducing CO<sub>2</sub> Emissions from Fossil Fuel Power Plants

James E. Staudt, Ph.D

*For questions: [staudt@AndoverTechnology.com](mailto:staudt@AndoverTechnology.com)*

Bipartisan Policy Center


December 6, 2013

[www.AndoverTechnology.com](http://www.AndoverTechnology.com)

# Typical CO<sub>2</sub> Emissions by Fuel and Cycle -Power Plants

Technology	CO <sub>2</sub> , short tons/MWhr
Coal (Subcritical)	~1 .0 +
Coal (Supercritical)	~0.89
Coal (UltraSupercritical)	~0.78
Natural Gas Boiler (Subcritical)	~0.55-0.60
Natural Gas Combined Cycle	~0.40-0.50
Biomass	0 - ??
Wind/PV/Nuclear	0

# Spectrum of Approximate Power Plant CO<sub>2</sub> Emissions (lbs/MWh)



# Reducing CO<sub>2</sub> Emissions from Existing Coal

- **Heat Rate Improvement**
  - Improving boiler efficiency
  - Improving steam plant efficiency
  - Reducing auxiliary loads
- **Less Carbon-Intensive Fuels**
  - Gas co-firing or reburn
  - Gas conversion
  - Cofiring of biomass or biomass conversion/repower
- **CCS**
  - Unlikely to play a significant role

# Potential Approaches for HR Improvement

- Coal Drying (esp., lignite coals)
- Variable Speed Drives
- Centrifugal to Axial fan conversion
- Steam turbine modifications
- Intelligent soot-blowing system
- New APH seals
- Repair boiler casing and duct in-leakage
- Condenser cleaning

# Questions on Heat Rate Improvement

- Will a HR improvement provide a positive return?
- What is the current condition of the unit?
  - For some units may be little opportunity for further improvement
- What is the planning horizon?
- NSR trigger?
- What is the economic environment?
  - merchant versus utility
  - investor owned versus co-op versus government owned
  - local market dynamics for power
  - company budget constraints

# Gas Conversion/Cofiring/Reburn

- **Conversion** (convert to 100% gas)
  - Being pursued by several utilities
  - Capital cost ~\$80/kW (with gas on site)
- **Cofiring/Reburning** (10-15% gas)
  - Modest cost (somewhat higher for reburn), assuming gas is on site
  - Reburning may allow for additional NO<sub>x</sub> reduction

# Biomass

- **Co-firing \***
  - Pulverized Coal ~\$500-600/kW
  - Cyclone ~\$300-400/kW
- **Repower**
  - PC to biomass fired CFB
    - (50 MW Schiller) \$1600-1700/kW\*\*

\* Renewable Energy Technical Assessment Guide—TAG-RE: 2006. EPRI, Palo Alto, CA: 2007. 1012722 and escalated to 2012 dollars

\*\* escalated to 2012 dollars.



# Improving HR for Gas Turbines

- Compressor inlet modifications (guide vanes, etc.)
- Inlet Air Cooling
- Combustor upgrades
- Hot section coatings
- New seals

# Recap

- Most likely options for existing coal to reduce CO<sub>2</sub> emissions are heat rate improvement or lower carbon fuel
  - No “one size fits all” solution
  - Best choice determined by several factors
  - CCS not expected to play a significant role
- Options for HR improvement exist for gas turbines as well
  - May also increase power output
- Methods that are low in capital and offer optionality will be preferred.